



GOVERNMENT OF KERALA

REGIONAL ANALYTICAL LABORATORY
KAKKANAD, ERNAKULAM. Pin 682030
E-mail: regionalanalyticallabernakulam@gmail.com

TEST REPORT

Issue Date. 04.06.2024

Report No.10199/B/24-25

Particulars of the sample : Drinking Water (Well)	Name & Address of Customer :- Mar Gregorious Memorial Public School, Kandanadu, Ernakulam – 682 305
Date of receipt of sample : 20.05.2024	
Date of Analysis : 20.05.2024 – 04.06.2024	
Condition of Sample : Fit for Analysis	
Sample Description : Clear, Colourless, Odourless liquid	Sample Quantity received : 2 L + 125 ml
	Type of packing : Plastic Can + Sterile Bottle

MICROBIOLOGICAL TESTING

SL No.	Parameters	Unit	Test Method	Result	Acceptable Limit as per IS 10500 : 2012 (With Amendment No. 1, 2, 3 & 4)
1	Coliforms	MPN/100 ml	IS 1622 1981 RA 2019	<2	Less than 2
2	E.Coli	--	IS 1622 1981 RA 2019	Absent/100 ml	Shall be absent

Note:

1. The test report relates to the tested parameters and to the tested item (as received) only.
2. The report shall not be reproduced except in full without approval of the Laboratory.
3. In Test report the decision rule of the laboratory is applied as and when required.
4. The complete report includes both A and B reports

-End of the Report-

Thara J
Authorized Signatory

