



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY
VELLAYAMBALAM, THIRUVANANTHAPURAM
 Telephone No - 0471-2735303, E-mail - aecqualitytvm@gmail.com



Test Report

Test Report. No -KWA/QCDL/TVM/2023/1696

ULR No.: TC956723000001546F

Date of Report : 17.05.2023

Customer Name & Address		1. Date of Receipt : 11.05.2023			
PONMUDY VALLEY PUBLIC SCHOOL VITHURA, TRIVANDRUM. PH:9862579335		2. Sampling done by : The Customer (QUA 60487)			
		3. Sample Code : 2023/1696			
		4. Sample Particulars : Drinking Water			
		5. Sample Quantity :2 litre			
		6. Test Performing Dates From : 11.05.2023 To : 15.05.2023			
Sl. No.	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Turbidity	(NTU)	IS 3025 (Part 10) - 1984) Nephelometric Method	1	0.09
2	pH at 25°C	-	IS 3025 (Part 11)- 2022 Electrometric Method	6.5 to 8.5	7.17
3	Total Hardness (as Ca CO ₃)	(mg/litre)	IS 3025 (Part 21) - 2009 EDTA method	200	4.1
4	Chloride (as Cl)	(mg/litre)	IS 3025 (Part 32) : 1988 Argentometric method	250	7.8

Remarks:-

NB:- 1. The results stated above related only to the sample(s) received for testing.

2. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Analyzed by *[Signature]*

SENIOR CHEMIST
QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
VELLAYAMBALAM

Authorized By

* End of Report *

SEENA. H

KWA/QCDL/TVM/R/41	Issue No:2	Issue Date 31.05.2022
Rev.No: 00	Rev Date: 26.04.2023	Page 1 of 1



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY

VELLAYAMBALAM, THIRUVANANTHAPURAM
Telephone No - 0471-2735303, E-mail - aequalityvm@gmail.com

Test Report

Test Report. No -KWA/QCDL/TVM/2023/1696

Date of Report : 17.05.2023

Customer Name & Address			1. Date of Receipt : 11.05.2023		
PONMUDY VALLEY PUBLIC SCHOOL, VITHURA, TRIVANDRUM. PH:9862579335			2. Sampling done by : The Customer (QUA 60487)		
			3. Sample Code : 2023/1696		
			4. Sample Particulars : Drinking Water		
			5. Sample Quantity : 2 litre		
			6. Test Performing Dates		
			From : 11.05.2023		
Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result	
1. Electrical Conductivity at 25 °C	(micro mhos/cm)	IS 3025 (Part 14) - 2013	-	35.20	
2. Iron (as Fe)	(mg/litre)	IS 3025 (Part 53) - 2003 1. 10 Phenanthroline Method	1.0	NIL	
3. Nitrate (as NO ₃)	(mg/litre)	APHA 23rd Edition 4500 - NO ₃ - B : 2017 UV Spectrophotometric Screening Method	45	1.53	

Remarks:-

- NB:- 1. The results stated above related only to the sample(s) received for testing
2. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Analyzed by:

Swathy

Authorized By

SEENA.H

* End of Report *

SEENA.H

KWA/QCDL/TVM/R/41	Issue No:2	Issue Date 31.05.2022
Rev.No: 00	Rev Date:26.04.2023	Page 1 of 1



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY
 VELLAYAMBALAM, THIRUVANANTHAPURAM
 Telephone No - 0471-2735303, E-mail - aeequalitytvm@gmail.com

Test Report

Test Report. No -KWA/QCDL/TVM/2023/1696


Date of Report : 17.05.2023

Customer Name & Address		1. Date of Receipt : 11.05.2023		
PONMUDY VALLEY PUBLIC SCHOOL VITHURA, TRIVANDRUM. PH:9862579335,		2. Sampling done by : The Customer (QUA_60487)		
		3. Sample Code : 2023/1696		
		4. Sample Particulars : Drinking Water		
		5. Sample Quantity :2 litre		
		6. Test Performing Dates From : 11.05.2023 To : 12.05.2023		
Sl. No.	Parameters	Acceptable limits as per IS 10500-2012	Test Method	Result
1	Total Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 ISO 9308 - 1 : 2014	ABSENT
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 ISO 9308 - 1 : 2014	ABSENT

Remarks:-

- NB:- 1.The results stated above related only to the sample(s) received for testing.
 2.This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Authorized By



* End of Report *

KWA/QCDL/TVM/R/41	Issue No:2	Issue Date 31.05.2022
Rev.No: 01	Rev Date:26.04.2023	Page 1 of 1

No. 135/23

PH NO: 6/2023-24

SANITARY CERTIFICATE

Certified that the Sanitary Arrangements made, Hygiene, maintained and the waste disposal management done for PONMUDI VALLEY PUBLIC SCHOOL Channuram, Vthiuram, in Building No. 3/520 of Tholicode Panchayath, under the management of PONMUDI VALLEY SCHOOL, was found satisfactory and the conditions suggested by PH Ordinance 2022 are fulfilled at the time of my visit on 19/6/2023. This Certificate is issued to produce before the CENTRAL BOARD OF SECONDARY EDUCATION.

Malayali
23.6.2023.



പെൻഷൻ ഇൻസ്പെക്ടർ
പ്രാഥമികാരോഗ്യകേന്ദ്രം
മലയാടി, പിൻ-695 542.